CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD SAN DIEGO REGION

ORDER NO. 98-91

AN ORDER RESCINDING CLEANUP AND ABATEMENT ORDER NO. 93-83 CLEANUP AND ABATEMENT OF DIESEL CONTAMINATED SOIL AT 39110 CONTRERAS ROAD, ANZA RIVERSIDE COUNTY

The California Regional Water Quality Control Board, San Diego Region (hereinafter RWQCB) finds that:

- Cleanup and Abatement Order No. 93-83 was issued on July 30, 1993 to GTE California, Incorporated (hereinafter referred to as the discharger) in response to an unauthorized release of petroleum hydrocarbons from the underground storage tank system located at 39110 Contreras Road, Anza, Riverside County California.
- 2. The unauthorized release of petroleum hydrocarbons from the leaking underground storage tank (UST) system resulted in elevated levels of Total Petroleum Hydrocarbons (TPH) in the diesel fuel range and low levels of Benzene, Toluene, Ethylbenzene, and Xylenes (BTEX). These contaminants were detected in soil at the site.
- 3. The discharger removed the leaking UST system in 1988 and conducted a preliminary site assessment, and later a vapor extraction pilot study was completed in 1996. An extraction system was never implemented. The discharger has demonstrated that further remediation is not necessary, and that residual contamination does not pose a significant threat to water quality.
- 4. Cleanup and Abatement Order (CAO) No. 93-83 issued for the cleanup of diesel contaminated soil is no longer necessary. A no further action letter will also be issued pursuant to Section 2721(e) of Title 23 of the California Code of Regulations.
- 5. This enforcement action is exempt from the provisions of the California Environmental Quality Act (Public Resources Code, Section 21000 et seq.) in accordance with Section 15321, Chapter 3, Title 14, California Code of Regulations.

IT IS HEREBY ORDERED,

1. Cleanup and Abatement Order No. 93-83 is hereby rescinded.

HN H. ROBERTUS

Executive Officer

Date: September 9, 1998